



SECTION 08625

TUBULAR DAYLIGHTING DEVICE

Display hidden notes to specifier. (Don't know how? [Click Here](#))

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Tubular daylighting device, consisting of roof dome, reflective tube, and diffuser assembly; configuration as indicated on the Drawings.

1.2 RELATED SECTIONS

- A. Section 07311 - Asphalt Shingles: Flashing of skylight base.
- B. Section 07320 - Roof Tiles: Flashing of skylight base.
- C. Section 07510 - Built-Up Bituminous Roofing: Flashing of skylight base.
- D. Section 07530 - Electrometric Membrane Roofing: Flashing of skylight base.
- E. Section 07550 - Modified Bituminous Membrane Roofing: Flashing of skylight base.
- F. Section 07600 – Flashing: Metal curb flashings.
- G. Section 08620 - Unit Skylights: Skylights without reflective tube.
- H. Section 08630 - Metal Framed Skylights.

1.3 REFERENCES

- A. ASTM B 209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- B. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2008a.
- C. ASTM A 463/A 463M - Standard Specification for Steel Sheet, Aluminum Coated, by the Hot Dip Process; 2006.
- D. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized), by the Hot Dip Process; 2007.
- E. ASTM A792/A 792M – Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process

- F. ASTM E 283 - Test Method for Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2004.
- G. ASTM E 308 - Standard Practice for Computing the Colors of Objects by Using the CIE System; 2006.
- H. ASTM E 330 - Structural Performance of Exterior Windows, Curtain Walls and Doors; 2002.
- I. ASTM E 547 - Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain walls by Cyclic Air Pressure Difference; 2000.
- J. ASTM E 1886 - Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.
- K. ASTM E 1996 - Standard Specification for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Windborne Debris in Hurricane
- L. ASTM D 635 - Test Method for Rate of Burning and/or Extent of Time of Burning of Self-Supporting Plastics in a Horizontal Position; 2006.
- M. ASTM D-1929 - Test Method for Ignition Properties of Plastics; 1996 (2001).
- N. ICC AC-16 - Acceptance Criteria for Plastic Skylights; 2008.
- O. Florida Building Code TAS 201 – Impact Test Procedures.
- P. Florida Building Code TAS 202 – Criteria for Testing Impact and Non Impact Resistant Building Envelope Components Using Uniform Static Air Pressure Loading.
- Q. Florida Building Code TAS 203 – Criteria for Testing Products Subject to Cyclic Wind Pressure Loading

1.4 PERFORMANCE REQUIREMENTS

- A. Completed tubular daylighting device assemblies shall be capable of meeting the following performance requirements:
 - 1. Air Infiltration Test: Air infiltration will not exceed 0.30 cfm/sf aperture with a pressure delta of 1.57 psf across the tube when tested in accordance with ASTM E 283.
 - 2. Water Resistance Test: No uncontrolled water leakage with a pressure differential of 2.92 psf (140 Pa) or 15 percent of the design load (whichever is greater) and a water spray rate of 5 gallons/hour/sf for 24 minutes when tested in accordance with ASTM E 547.
 - 3. Water Resistance Test: No uncontrolled water leakage at 10.5 psf pressure differential with water rate of 5 gallons/hour/sf when tested in accordance with ASTM E 547.
 - 4. Uniform Load Test:
 - a. No breakage, permanent damage to fasteners, hardware parts, or damage to make daylighting system inoperable or cause excessive

- permanent deflection of any section when tested at a Positive Load of 210 psf (10.05 kPa) or Negative Load of 160 psf (7.66 kPa) in accordance with ICC AC-16 Section A.
 - b. No breakage, permanent damage to fasteners, hardware parts, or damage to make system inoperable or cause excessive permanent deflection of any section when tested at a Positive Load of 150 psf (7.18 kPa) or Negative Load of 60 psf (2.87 kPa) in accordance with ICC AC-16 Section A, or Negative Load of 70 psf (3.35 kPa) if tested per ICC AC-16 Section B.
 - c. No breakage, permanent damage to fasteners, hardware parts, or damage to make daylighting system inoperable or cause excessive permanent deflection of any section when tested at a Positive Load of 150 psf (7.18 kPa) or Negative Load of 70 psf (3.35 kPa).
 - d. All units shall be tested with a safety factor of (3) for positive pressure and (2) for negative pressure, acting normal to plane of roof in accordance with ASTM E 330.
5. Hurricane Resistance:
- a. Meets Florida Building Code TAS, 201, TAS, 202 and TAS 203 for Impact and non impact components.
 - b. Meets ASTM E 1886 and ASTM E1996 for missile and cyclic pressure differential testing.
6. Fire Testing:
- a. When used with the Dome Edge Protection Band, all domes meet fire rating requirements as described in the International Building Code.
 - b. Self-Ignition Temperature - Greater than 650 degrees F per ASTM D-1929.
 - c. Smoke Density - Rating no greater than 450 per ASTM Standard E 84 in way intended for use. Classification C.
 - d. Rate of Burn and/or Extent - Maximum Burning Rate: 2.5 inches/min (62 mm/min) Classification CC-2 per ASTM D 635.
 - e. Rate of Burn and/or Extent - Maximum Burn Extent: 1 inch (25 mm) Classification CC-1 per ASTM D 635.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings. Submit shop drawings showing layout, profiles and product components, including anchorage, flashings and accessories.
- D. LEED Submittals: Provide documentation of how the requirements of Credit will be met:
 - 1. List of Daylight Credits available for the products specified.
 - 2. Data on Energy Optimization Performance Credits for the products specified.
 - 3. Data on Perimeter and Non-Perimeter Controllability of Systems for use of Daylight Dimmer option with the products specified.
 - 4. Data on potential Innovation in Design Credits which may be available for the innovative use of the products specified.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Engaged in manufacture of tubular daylighting devices for minimum 20 years.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- A. Daylighting Device: Manufacturer's standard warranty for 10 years.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Solatube International, Inc.; 2210 Oak Ridge Way, Vista, CA 92081. ASD. Tel. Toll Free: 888-765-2882. Tel: (760) 477-1120. Fax: (760) 597-4488. Email: commsales@solatube.com. Web: www.solatube.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 TUBULAR DAYLIGHTING DEVICES

- A. Tubular Daylighting Devices General : Transparent roof-mounted skylight dome and self-flashing curb, reflective tube, and ceiling level diffuser assembly, transferring sunlight to interior spaces; complying with ICC AC-16.
- B. SkyVault Series: Solatube Model M74 DS - O Open Ceiling, 28.5 inch (724 mm) Daylighting System:
 - 1. Roof Dome Assembly: Transparent, UV and impact resistant dome with flashing base supporting dome and top of tube.
 - 2. Fasteners: Non-corrosive metal fasteners including: non-magnetic stainless steel, zinc plated steel, aluminum, or injection molded nylon.
 - 3. Outer Dome Glazing: Type DP, 0.125 inch (3.2 mm) minimum thickness vacuum formed polycarbonate classified as CC1 material; UV inhibiting (Blocks all radiation <380nm: 100 percent UVC, 100 percent UVB and 76 percent of the range of UVA transmission).

- a. Outer Dome Seals: Adhesive Back Closed Cell Foam Seal 0.25 inch (6.3 mm) tall by 0.75 inch (19 mm) wide.
- 4. Dual Dome Glazing:
 - a. Outer Dome Glazing: Type DP, 0.125 inch (3.2 mm) minimum thickness vacuum formed polycarbonate classified as CC1 material; UV inhibiting (Blocks all radiation <380nm: 100 percent UVC, 100 percent UVB and 76 percent of the range of UVA transmission).
 - b. Inner Dome Glazing: Type DPP, 0.040 inch (1 mm) minimum thickness copolyester (PETG) polyethylene terephthalate with glycol classified as CC1 material.
 - c. Seals:
 - 1) Inner Dome Seal: Adhesive back closed cell foam seal 0.125 inch (3.2 mm) or 0.188 inch (4.8 mm) tall by 0.375 inch (9.5 mm) wide.
 - 2) Dome Assembly Seal: Adhesive backed pile weather-strip, 0.350 inch (8.9 mm) tall by 0.187 inch (4.8 mm) wide.
- 5. Security Guard: Type SG, welded powder coated steel or stainless steel rods 1/4 inch diameter mounted with an 8 inch maximum cross section. Assembly fastened with 1/8 inch diameter blind rivets in 6 locations to Curb-Cap assembly. Use non-removable machine screws dome screws.
- 6. Curb Cap Flashing Base: One piece, seamless, leak-proof flashing and base support for dome and top of tube and cap flashing. Fabricated of galvanized steel, conforming to ASTM A 653/A 653M or ASTM A 463/A 463M or ASTM A792/A 792M, with a thickness of 0.0276 inch (0.7 mm) plus or minus .004 inch (.01 mm).
 - a. Base Style: Type FC, Curb-cap, with inside dimensions of 35.5 inches by 35.5 inches (902 mm by 902 mm) to cover curb specified in Section 07600.
 - b. Insulation: Nominal 1-inch thick thermal isolation pad to reduce thermal conduction between curb-cap and tubing and thermal convection between room air and curb-cap. Rated R-6 ($^{\circ}\text{F}\cdot\text{ft}^2\cdot\text{hr}/\text{Btu}$) Insulation is Polyisocyanurate foam utilizing CFC, HCFC, & HFC free blowing agent. Type-1 Class-1 per ASTM C1289; Passes UL 1715 (15-minute thermal barrier per IBC 2603.4); Attic ventilation may be required per IBC 1203.2
 - c. Curb Seal: Includes a double bead of adhesive backed closed cell foam seal 0.188 inch (4.8mm) tall by 0.375 inch (9.5mm) wide to reduce air infiltration.
- 7. Dome Edge Protection Band: For Classified Roof Assemblies. For approved assemblies, curb height (by others or built on site) must be more than 8 inches (203 mm). Galvanized steel. Nominal thickness of 0.039 inch (1 mm).
- 8. Tube Collar: Attached to top of curb-cap section; 0.018 inch (0.45 mm) nominal thickness aluminum.
 - a. Interior Finish: Spectralight Infinity high reflectance specular finish on exposed reflective surface. Specular reflectance for visible spectrum (400 nm to 760 nm) greater than 99 percent. Total solar spectrum reflectance (400 nm to 2500 nm) less than 80.2 percent.
 - b. Color: a^* and b^* (defined by CIE $L^*a^*b^*$ color model) shall not exceed plus 2 or be less than minus 2 as determined in accordance to ASTM E 308.
- 9. Reflective Tubes: Aluminum sheet, thickness 0.018 inch (0.5 mm) with Tab-Lock tube joint structural connection system.
 - a. Extension Tube:
 - 1) Reflective extension tube, Type E1, 24 inches (610 mm)

- 2) Reflective extension tube, Type EL, 48 inches (1220 mm) long.
 - 3) Belt Alignment Tab aligns Tube Belt on to tube in the correct location.
 - 4) Interior Finish: Spectralight Infinity high reflectance specular finish on exposed reflective surface. Specular reflectance for visible spectrum (400 nm to 760 nm) greater than 99 percent. Total solar spectrum reflectance (400 nm to 2500 nm) less than 80.2 percent.
 - 5) Color: a* and b* (defined by CIE L*a*b* color model) shall not exceed plus 2 or be less than minus 2 as determined in accordance to ASTM E 308.
- b. Tab-Lock
- 1) Tab-Lock captures adjoining tube or tube connector using periodic opposing hooks integrated in the tube perimeter with mating retention detents.
 - 2) Hook system allows ease of tube engagement or disengagement for single operator from man-lift or rooftop.
 - 3) System intertwines the ends of the adjoining tubes and tube connectors between each Tab-Lock station.
 - 4) Intertwining function accepts tubes and connectors of common diameters which reduces light loss up to 2 percent per tube joint relative to tubes with 0.3 inch (7.6 mm) diameter difference.
- c. Tube Belt:
- 1) Sheet-metal belt 2 inch (50.8mm) wide x 0.022 inch (0.5mm) thick CS-B AZ-50 ASTM A792 with 0.10 inch (2.5mm) diameter stainless steel type 302 ASTM A 313 torsion spring actuated toggle clamp.
 - 2) Retains Tab-Lock tube joint structural connection system; stiffens linear tube assembly; and prevents tube rotation or disengagement under normal use.
 - 3) Includes locking tab to prevent unintentional Tube Belt Latch opening due to handling, service, vibration, or normal operation or use.
10. Diffuser Assemblies for Tubes Not Penetrating Ceilings (Open Ceiling): Solatube Model M74 DS-O. 28.5 inch (724 mm) diameter diffuser attached directly to bottom of tube.
- a. Lens: Type L2, Prismatic lens designed to maximize light output and diffusion. Visible Light Transmission shall be greater than 90 percent at 0.100 inch (2.5 mm) thick. Classified as CC2.
 - b. Diffuser Seal: "L" shaped EPDM closed cell foam, , 0.86 in (21.8 mm) wide by 1.37 in (34.8mm) tall by 0.16 in (4.1 mm) thick to minimize condensation and bug, dirt and air infiltration per ASTM E 283.

2.3 ACCESSORIES

- A. Fasteners: Same material as metals being fastened, non-magnetic steel, non-corrosive metal of type recommended by manufacturer, or injection molded nylon.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.

- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's printed instructions.
- B. After installation of first unit, field test to determine adequacy of installation. Conduct water test in presence of Owner, Architect, or Contractor, or their designated representative. Correct if needed before proceeding with installation of subsequent units.
- C. Inspect installation to verify secure and proper mounting. Test each fixture to verify operation, control functions, and performance. Correct deficiencies.

3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION